

CITY OF TUCKER

ACKNOWLEDGE RECEIPT OF ADDENDUM #3 FORM

ITB 2024-010

TUCKER TOWN GREEN CONSTRUCTION

Upon receipt, please print and add to your proposal.

I hereby acknowledge receipt of the supplement pertaining to the above referenced bid.

COMPANY NAME: _____

CONTACT PERSON: _____

ADDRESS: _____

CITY: _____ STATE: _____ ZIP: _____

PHONE: _____ FAX: _____

EMAIL ADDRESS: _____

SIGNATURE

DATE

ITB 2024-010
ADDENDUM #3

	QUESTION	ANSWER
1	Is Davis-Bacon wage applicable to the Tucker Town Green project?	No.
2	Could you provide detailed information about the recreation berms included in the project plans?	Additional berm information included in Addendum #2
3	Would it be possible to obtain access to the CAD files for the Tucker Town Green project?	CAD files will be provided to the awarded bidder.
4	Could unit pricing be incorporated to address the unsuitable soil conditions outlined in the Geotechnical report?	Yes. Contractor may submit a per cubic yard unit price for removal of unsuitable soils and the placement of engineered fill, as outlined in the Geotechnical report.
5	Is there a designated landfill site where the unsuitable soil from the project must be disposed of?	No. The awarded bidder will be responsible for selecting disposal site and funding that effort.
6	Is backfilling required for the RCP used in the project?	Backfilling IS required for the RCP
7	Can HDPE be used in place of RCP for Storm on the project?	HDPE MAY NOT be used in place of RCP
8	Is GDOT prequalification necessary for subcontractors involved in the Tucker Town Green project?	GDOT Prequals. are NOT necessary