

CITY OF TUCKER

ACKNOWLEDGE RECEIPT OF ADDENDUM #1 FORM

ITB 2024-012

HUGH HOWELL TRAIL PHASE II CONSTRUCTION

Upon receipt, please print and add to your proposal.

I hereby acknowledge receipt of the supplement pertaining to the above referenced bid.

COMPANY NAME: _____

CONTACT PERSON: _____

ADDRESS: _____

CITY: _____ STATE: _____ ZIP: _____

PHONE: _____ FAX: _____

EMAIL ADDRESS: _____

SIGNATURE

DATE

ITB 2024-012
ADDENDUM #1

	QUESTION	ANSWER
1	Is there a geotechnical report for this project?	No, a geotechnical report has not been done.
2	Can you please provide Utility Adjustment Schedule (UAS) for the project as there are some utilities which will need to be relocated?	Utility coordination will be the responsibility of the contractor. Georgia Power, AT&T, Zayo Communications, and Atlanta Gas utilities require relocation.
3		ADDED Special Condition #11: All Class B Concrete, Retaining Wall, materials must be tested according to the GDOT Sampling, Testing, and Inspection Manual by an approved consultant/lab hired by the Contractor. Test results must pass all required GDOT minimums and results must be submitted to the City Superintendent before use.