

CITY OF TUCKER

ACKNOWLEDGE RECEIPT OF ADDENDUM #1 FORM

ITB 2024-0013

HUGH HOWELL SIDEWALK CONSTRUCTION

Upon receipt, please print and add to your proposal.

I hereby acknowledge receipt of the supplement pertaining to the above referenced bid.

COMPANY NAME: _____

CONTACT PERSON: _____

ADDRESS: _____

CITY: _____ STATE: _____ ZIP: _____

PHONE: _____ FAX: _____

EMAIL ADDRESS: _____

SIGNATURE DATE

ITB 2024-013
ADDENDUM #1

	QUESTION	ANSWER
1	Is it possible to get a link to plans and specs to take a look at the retaining wall requirements?	The plans were linked with the original ITB. The retaining wall typical section is located on page 05-0001. The note at the bottom left of the page, B, states to reference GA standard 9031L for the class B concrete retaining wall.
2		ADDED Special Condition #11: All Class B Concrete, Retaining Wall, materials must be tested according to the GDOT Sampling, Testing, and Inspection Manual by an approved consultant/lab hired by the Contractor. Test results must pass all required GDOT minimums and results must be submitted to the City Superintendent before use.